

Facilities and Maintenance Committee Report
3.12.25 – 4.15.25

- **LEC**
 - **Kitchen backsplash needed**
 - **Cell block 24 LED fixtures installed**
 - **Backflow testing due**

- **NCH**
 - **4th floor flooring, 40% complete**
 - **4th floor painting 100% complete**
 - **Sound proofing courtrooms ceilings 75% complete**
 - **Backflow testing, failed** (backflow check valve rebuild needed)
 - **LED lamp replacement 1st, 2nd, 3rd floors start 4/17**

- **OCH**
 - **Pro Com to install card reader on N. Entrance, Dixon Glass will remove old hinges and install full length exterior mount hinges with openers.**
 - **Roof leak needs identified and fixed**
 - **Building static pressure troubleshooting resolved**
 - **Generator starter failed; factory service scheduled?**
 - **Backflow test complete, water pressure after the meter is low, needs pressure valve replacement**

- **AC**
 - **Kennel side of building needs siding repair or replaced**

- **FMD**
 - **Mowing season starts**
 - **I-Pad's for Maintenance Tech's**